LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material
170	187	17	Lt Brn Clay
*187	195	8	gravel and Water *
195	201	6	Rock
*201	221	20	gravel & Water *
221	225	4	Rock

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 3/8 I.D.	0	225	225	gravel packed from 225 ft to 60 ft grouted from 60 ft to 0 - using 6 sack mix of W.M.K Co well grout

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Pumping test - static water level is 70 ft - Bailed 20 min removing 500 gallons of water - Drawed down to 105 ft recovered static water level of 73 ft in 20 minutes

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Douglas Slagle
Well Driller

By Self

License No. 137

Dated Oct 28, 1961

(Not to be filled in by Driller)