

OFFICE USE ONLY  
Log No. 58933  
Permit No. \_\_\_\_\_  
Basin. 105

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28478

1. OWNER RICK DABNEY CONST ADDRESS AT WELL LOCATION 853 MARION GARDNERVILLE  
MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 17 T. 12 N. R. 20 E. DOUGLAS County  
PERMIT NO. 27-672-06 CHAMBERS FIELD Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Cobbles, gravel <sup>some</sup> sandy clay</u>		<u>3</u>	<u>38</u>	<u>35</u>
<u>Sandy clay &amp; gravel</u>		<u>38</u>	<u>43</u>	<u>5</u>
<u>Cobbles, gravel &amp; sandy clay</u>		<u>43</u>	<u>77</u>	<u>34</u>
<u>Sandy clay &amp; gravel</u>		<u>77</u>	<u>83</u>	<u>6</u>
<u>gravel &amp; short strds. <sup>sandy</sup> clay</u>		<u>83</u>	<u>123</u>	<u>40</u>
<u>Sandy clay &amp; gravel</u>		<u>123</u>	<u>127</u>	<u>4</u>
<u>gravel &amp; short strds. <sup>sandy</sup> clay</u>	<u>✓</u>	<u>127</u>	<u>140</u>	<u>13</u>

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
10 5/8 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 140 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>140</u>

Perforations:  
Type perforation FACTORY SLOTTED  
Size perforation 3 x 1/8  
From Factory 120 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 100 feet to 140 feet

9. WATER LEVEL  
Static water level 28 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COLD °F Quality GOOD

Date started 6-3, 1996  
Date completed 6-5, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor  
Address 7780 CURRY RD Contractor  
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed Jerald W. Drimmel  
By driller performing actual drilling on site or contractor  
Date 6-10-96