WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 59226
Permit No.
Basin 162

NOTICE OF INTENT NO. 15217

1. OWNER KUZMICH, REGINA
MAILING ADDRESS 1281 CASH
PAHRUMP, NV 89041

ADDRESS AT WELL LOCATION 1281 CASH

2. LOCATION SE 1/4 SW 1/4 Sec. 11 T 21S N/S R 53E E NYE County
PERMIT NO. _____ Issued by Water Resources | 44-361-04 Parcel No. | THOUSANDAIRE EST Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHIE		0	63	63
CALICHIE	WB	63	82	19
CLAY		82	95	13
CALICHIE	WB	95	107	12
CLAY		107	125	18
CALICHIE	WB	125	140	15

DCNR/DWR Received JAN 3 1997

Date started 12/16/96, 19__
Date completed 12/19/96, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3
From 100 feet to 120 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL

Static water level 53 feet below land surfac
Artesian flow _____ G.P.M. _____ P.S.I
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Co.
Contractor

Address PO BOX 4220
Contractor

PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dan
By driller performing actual drilling on-site or contractor

Date 12/19/96