



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Burt Griffith ADDRESS 8812 Giles St. Las Vegas, Nevada.

2. LOCATION SW 1/4 SW 1/4 Sec 16 T 22 N/S R. 6/ E Clark County

PERMIT NO. Back of Stage Coach Inn, on Giles St. Las Vegas, Nevada

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil and rocks		0	30	30
Conglomerate		30	70	40
Cemented gravel		70	120	50
Cemented gravel with red clay layers		120	140	20
Light colored clay with little sand		140	142	2
Cemented gravel		142	240	98
Cemented gravel with loose areas		240	290	50
Cemented gravel		290	302	12

RECEIVED
JUL 20 1970

DIVISION OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started April, 28, 1970
Date completed June, 14, 1970

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST			
G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 302 feet
 Casing record 8 5/8" O.D.
 Weight per foot 12# Thickness .135

Diameter	From	To	Thickness
<u>12</u> inches	<u>0</u>	<u>50</u>	<u>50</u> feet
<u>10</u> inches	<u>50</u>	<u>302</u>	<u>302</u> feet

Surface seal: Yes No Type Cemented
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from feet to feet

Perforations:
 Type perforation Vertical Slot
 Size perforation 3/16" x 5"
 From 222 feet to 302 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

9. WATER LEVEL

Static water level 114 Feet below land surface 114
 Flow G.P.M. Quality Good
 Water temperature 70 ° F.

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Weimer Drilling

Address 9051 S. Mohawk St. Las Vegas, Nev.

Nevada contractor's license number 5962A

Nevada driller's license number 171

Signed H V Weimer

Date July, 14 - 1970