DIVISION OF WATER RESOURCES

Deeping Gullard well

Robert O'Connor

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59579
Permit No.
Basin 212

1. OWNER ~~Paul E Specht~~ ADDRESS ~~253 Windmill~~
8140 La Cienega (2 homes) 253 Windmill

2. LOCATION NW ¼ NE ¼ Sec. 16 T. 22S N/S R. 61 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay & Pea gravel		197	297	100
(gravel packed, & gravel comming in all the time impossible to tell what I was drill in except it wasnt soft				

RECEIVED
JUL 28 1975
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started July 1, 1975
Date completed July 2, 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 7" inches Total depth ~~100~~ 297 feet
Casing record 6" casing for liner
Weight per foot approx 12 Thickness 8 gage

Diameter	From	To
8 inches	0 feet	200 feet
6" inches	197 feet	297 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes Was No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation 1/8" x 12"
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 117 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Douglas Slagh
Address 6350 Las Vegas Blvd South
Nevada contractor's license number 3325
Nevada driller's license number 137
Signed Douglas Slagh
Date July 21 1975

USE ADDITIONAL SHEETS IF NECESSARY

5471