WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59615
Permit No.
Basin 212

1. OWNER Mike Terlizzi ADDRESS 225 W. New York, L.V. Nev.

2. LOCATION E½ SW¼ SE¼ Sec. 16 T. 22 S N/S R. 61 E. Clark County
PERMIT NO. NE¼ NW¼

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	4	4
Conglomerate		4	60	56
Lime shell		60	68	8
Cemented gravel		68	120	52
Hard shell		120	125	5
Red clay & gravell		125	135	10
Hard shell		135	145	10
Clay & sand	145	145	150	5
Clay + gravel	150	150	170	20
Cemented gravel		170	240	70
Cemented gravel with loose areas	240	240	250	10

Date started Nov 7, 19 79
Date completed Nov. 20, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
MAY 27 1980
Div. of Water Resources
Branch Office — Las Vegas, Nev.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 250 feet
Casing record 8 5/8 0 - 250
Weight per foot 17 lbs. Thickness .135

Diameter	From	To
8 5/8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cemented
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Vertical slots
Size perforation 1/8" x 4"
From 145 feet to 250 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 125 Feet below land surface
Flow ..... G.P.M.
Water temperature 69 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Weimer Drilling
Address 9057 Mohawk L.V. Nev
Nevada contractor's license number 5962A
Nevada driller's license number 171
Signed H. V. Weimer
Date Nov. 30 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

in Book

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59615
Permit No.
Basin 212

1. OWNER Mike Terlizzi ADDRESS 225 W. New York - Las Vegas, Nevada

S.W 1/4 - S.E 1/4 Shorborne on corner

2. LOCATION N.E. ¼ N.W. ¼ Sec. 16 T. 22 N/S R. 61 E. Clark County

PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Conglomorate		4	60	56
Lime Shell.		60	68	8
Cemented Gravel.		68	120	52
Lime Shell.		120	125	5
Red clay mix gravel.		125	135	10
Lime Shell.		135	145	10
Lime Shell little sand	145	145	150	5
Clay mix gravel strata	150	150	170	20
Cemented Gravel + sand		170	240	90
Cemented Gravel mix loose areas	240	240	250	10

Date started May - 20, 19 79
Date completed May - 15, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
JUL 02 1979
Div. of Water Resources
Branch Office — Las Vegas, Nev.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 250 feet
Casing record 8 5/8" O.D. - 0' to 250
Weight per foot 14# Thickness .135

Diameter	From	To
8 5/8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cemented
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Vertical Slot
Size perforation 1/8" x 4"
From 145 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 125 Feet below land surface
Flow G.P.M.
Water temperature 69 °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Weimer Drilling.
Address 9051 S. Mohawk St. Las Vegas Nv. 89118
Nevada contractor's license number 5962A
Nevada driller's license number 171
Signed H. V. Weimer
Date July - 1 - 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471