

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 59675
 Permit No. _____
 Basin. _____

1. OWNER Ed Hicks ADDRESS S. Gateway

2. LOCATION NE 1/4 NE 1/4 Sec. 31 T. 21 N/S R. 62 E Clark County
 PERMIT NO. _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
silt		0	26	
gravel	X	26	26 1/2	1/2
clay		26 1/2	60	
gravel	X	60	61	
clay		61	78	
gravel	X	78	79	
clay		79	120	
lime rock	X	120	130	
clay		130	176	
gravel	X	176	178	
clay		178	200	

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 200 feet
 Casing record _____
 Weight per foot 12.4 Thickness 10 ga.

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 200 feet

Perforations:

Type perforation torch
 Size perforation 1/8 X 10

From	To
<u>60</u> feet	<u>65</u> feet
<u>80</u> feet	<u>85</u> feet
<u>118</u> feet	<u>126</u> feet
<u>170</u> feet	<u>200</u> feet

RECEIVED
 JUL 5 1977

Div. of Water Resources
 Branch Office — Las Vegas, Nev.

Date started June 13 1977
 Date completed June 15 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 60 Draw down 25 feet 1/2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 10 Feet below land surface
 Flow _____ G.P.M.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name M.D. Briner
 Address 1947 Parkson Rd. Henderson
 Nevada contractor's license number 6294A
 Nevada driller's license number 693
 Signed M.D. Briner
 Date June 5, 1977

