

Log No. 59705
 Permit No. _____
 Basin. _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Nick Mc Gaugh ADDRESS Las Vegas, Nevada

2. LOCATION NW 1/4 NW 31 T. 21 N/S R. 62 E. Clark County
 PERMIT NO. _____

3.	TYPE OF WORK			4.	PROPOSED USE			5.	TYPE WELL	
	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Other <input type="checkbox"/>		Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>		Cable <input type="checkbox"/>	Rotary <input type="checkbox"/>
	Deepen <input type="checkbox"/>			Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>				

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Clay		2	30	28
Tight lime		30	38	8
Clay		38	52	14
Clay, little sand	52	52	65	11
Red clay		65	95	30
Red clay with sand and gravel	95	95	125	30
Red clay and gravel	125	125	145	20
Sand and gravel with little clay	145	145	200	55

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 200 feet
 Casing record _____
 Weight per foot 13# Thickness .135

Diameter	From	To
<u>8 5/8"</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cemented
 Depth of seal 80 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Vertical slot
 Size perforation 3/4" x 7"
 From 140 feet to 200 feet
 From _____ feet to _____ feet

RECEIVED
 NOV 15 1976
 Div. of Water Resources
 Branch Office — Las Vegas, Nev.

Date started 11/10, 1976
 Date completed 11/15, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours


9. WATER LEVEL

Static water level 15 Feet below land surface
 Flow _____ G.P.M.
 Water temperature 68 ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WEIMER DRILLING
 Address 99518 Mohawk St. Las Vegas, NV.
 Nevada contractor's license number 5962A
 Nevada driller's license number 171
 Signed H. V. Weimer
 Date 11-17-76



17

17