

**WELL DRILLERS REPORT**

Please complete this form in its entirety

Log No. 59870  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 0896

PRINT OR TYPE ONLY

OWNER William Davis ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SW 1/4 Sec. 22 T. 19 N/S R. 60 E CLARK County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND + ROCKS		0	4	4
Calch		4	28	24
Brctime		28	31	3
Clay		31	202	171
Calch		202	245	43
Clay w/ STRAK OF GRAVEL		245	430	185

8. WELL CONSTRUCTION  
 Diameter hole 10" inches Total depth 430 feet  
 Casing record 0-430  
 Weight per foot \_\_\_\_\_ Thickness 156  

Diameter	From	To
<u>6 7/8</u> inches	0	430
_____ inches	_____	_____

 Surface seal: Yes  No  Type CMT  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 430 feet  
 Perforations:  
 Type perforation Cutting torch  
 Size perforation 00  
 From 300 feet to 430 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 FEB 3 1983  
 Div. of Water Resources  
 Branch Office - Las Vegas, Nev.

Date started 11-29 1982  
 Date completed 12-2- 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name LIEG R. THOMAS Contractor  
 Address 5965 N. MADRICK L.V. Contractor  
 Nevada contractor's license number 10831  
 Nevada contractor's drillers number 623  
 Nevada driller's license number 623 Actual Driller  
 Signed L.R. Thomas Contractor  
 Date 2-2-83

BAILER TEST

G.P.M.	Draw down	feet	hours