DIVISION OF WATER RESOURCES
CLIENT'S COPY
WELL DRILLER'S COPY

Well #1

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59884
Permit No.
Basin 212

1. OWNER Zoltan Hegyeli ADDRESS 5895 Edna Av Las Vegas Nev

2. LOCATION NE ¼ NW ¼ Sec. 14 T. 19 N/S R. 60 E. Clark County
PERMIT NO.

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Caliche		0	10	10
white Clay		10	130	120
Brown Clay		130	150	20
Brown limestone		150	155	5
Brown Clay	✓	155	175	20
White limestone	✓	175	185	10
Redish Brown Clay w/gravel	✓	185	300	115

RECEIVED
MAR 17 1981
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 10-5-80, 19
Date completed 11-1-80, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 22 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 300 feet
Casing record 8"
Weight per foot 14 Thickness .156

Diameter	From	To
8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 300' feet

Perforations:
Type perforation Torch
Size perforation 1/8 x 12
From 200 feet to 300' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 120 Feet below land surface
Flow G.P.M.
Water temperature Cool °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vince Dresden
Address 2920 Beechwood Pl Las Vegas
Nevada contractor's license number 13577
Nevada driller's license number 968
Signed Vincent J Dresden
Date 3-15-81

USE ADDITIONAL SHEETS IF NECESSARY

5471