

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16640

1. OWNER Michael & Rebecca Smith ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4231 E. Mary Lou St. 4231 E. Mary Lou St.
Pahrump, NV 89048 Pahrump, NV 89048
 2. LOCATION SE 1/4 NW 1/4 Sec. 17 T. 21 N/S R. 54 E Nye County
 PERMIT NO. ADN 45-181-17 Lot 1 None
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. Domestic Municipal/Industrial
 5. PROPOSED USE Irrigation Test Monitor Stock
 6. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Soft Brown Clay		4	28	24
Brown Clay/Small Gravel		28	46	18
Brown Clay		46	80	34
Hard Limestone		80	88	8
Brown Clay	X	88	130	42
Brown Clay with Small Black Gravel	X	130	152	22
Hard Limestone		152	156	4
Brown Clay		156	160	4

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
1.2 Inches 0 Feet 1.60 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	131#	.138	0	160

Perforations:
 Type perforation Torch Cut
 Size perforation 1 1/4" width, 8" long
 From 120 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout
 Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 57' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address 1060 W. Basin Rd. Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg
 By driller performing actual drilling on site or contractor
 Date Jan. 15, 1997



Date started Jan 7, 1997
 Date completed Jan 9, 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

