DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 601166
Permit No.
Basin

1. OWNER Charles Sutton ADDRESS 5636 Donald, L.V.
WELL ADDRESS 5636 DONALD RD.

2. LOCATION N E¼ N W ¼ Sec. 24 T. 19 N/S R. 60 E Clark County
PERMIT NO. PARCEL # 125-24-104-001

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Calidhe		0	26	
White Clay		26	58	
Red Sand Clay		58	85	
Sandy Clay Water		85	100	
Clay		100	135	
Sandy Clay Water		135	160	
Clay		160	200	

RECEIVED
JUN 6 1974
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started November 12, 19 73
Date completed November 14, 19 73

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 200 feet
Casing record
Weight per foot Thickness 10 G A

Diameter	From	To
8 5/8 inches	+½ feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Torch
Size perforation ¼" x 18"
From 85 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 75 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon Dimick
Address 5434 West Alexander
Nevada contractor's license number 10062
Nevada driller's license number 552
Signed V. Dimick
Date June 5, 1974

USE ADDITIONAL SHEETS IF NECESSARY

5471