

OFFICE USE ONLY
 Log No. 60326
 Permit No. _____
 Basin 212



WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1266

OWNER Arnold Silverman/DBA ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Loan Mt. Trailer Park _____

2. LOCATION SE 1/4 SE 1/4 Sec. 33 T. 19 S N/S R. 60 W Clark County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other replacement

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>silty sand & gravel</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>brown clay</u>		<u>20</u>	<u>52</u>	<u>32</u>
<u>decompose caliche</u>		<u>52</u>	<u>56</u>	<u>4</u>
<u>clay with streaks</u>				
<u>of gravel</u>		<u>56</u>	<u>289</u>	<u>233</u>
<u>gravel with some</u>				
<u>clay</u>		<u>289</u>	<u>340</u>	<u>51</u>
<u>grey lime Med./hard</u>		<u>340</u>	<u>397</u>	<u>57</u>
<u>cemented congloven</u>		<u>397</u>	<u>470</u>	<u>73</u>

8. WELL CONSTRUCTION
 Diameter hole 12 inches Total depth 470 feet
 Casing record 8 5/8
 Weight per foot 14.11 Thickness 1.56

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>470</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 470 feet

Perforations:
 Type perforation torch
 Size perforation 1/8 x 4 4 around
 From 115 feet to 470 feet
 From _____ feet to _____ feet

RECEIVED
 DEC 12 1984
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started July 12, 1984
 Date completed July 16, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>air</u>	<u>200</u>		<u>1</u>

9. WATER LEVEL
 Static water level 168 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Allen Drilling Contractor
 Address 4847 Valley View Blvd. Contractor
 Nevada contractor's license number 018917
 Nevada contractor's drillers number 1301
 Nevada driller's license number 1376 Actual Driller
 Signed [Signature] Contractor
 Date 12-06-84

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours