


Log No. **60357**

Permit No. _____

Basin **212**



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER Ariel & Carrie Ornut ADDRESS AT WELL LOCATION Rosada & Tenaya
 MAILING ADDRESS 1708 Adra Ct.
Las Vegas, NV 89102

2. LOCATION NE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 34 T. 19 N/S R. 60 E. Clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden & Cliche		0	40	40
Clay & Boulders		40	80	40
Clay & few boulders		80	180	100
Clay & few boulders, gravel		180	220	40
White rock, boulder, clay		220	240	20
White rock, clay		240	260	20
White rock, clay, few boulder		260	280	20
White rock, clay		280	300	20
Red rock, clay, white rock		300	340	40
Red & white rock		340	360	20
Red & white rock, little gravel		360	380	20
Red rock, little white rock & gravel		380	420	40
Gravel, clay, sand, cent. sand		420	440	20
Sandy gravel, red rock		440	454	14

RECEIVED

APR 02 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 3-22 19 91
 Date completed 4-1 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

8. WELL CONSTRUCTION

Diameter 12 1/2 inches Total depth 454 feet
 _____ inches
 _____ inches

Casing record
 Weight per foot _____ Thickness .188

Diameter	From	To
_____ inches	<u>+1</u> feet	<u>454</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 450 feet

Perforations:
 Type perforation Mill slots
 Size perforation 1/8 x 3
 From 350 feet to 434 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 152 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. Contractor
4185 W. Harmon
 Address Las Vegas, NV 89103 Contractor

Nevada contractor's license number issued by the State Contractor's Board 4286A

Nevada contractor's driller's number issued by the Division of Water Resources 290

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1750

Signed Richard K. Thompson
 By driller performing actual drilling on site or contractor

Date April 2, 1991

