


Log No. 60655  
 Permit No. \_\_\_\_\_  
 Basin 212



**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. \_\_\_\_\_

PRINT OR TYPE ONLY

OWNER VICTOR AGUILAR ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 NE 1/4 Sec. 27 T. 19S N/S R. 61 E CLARK County  
 PERMIT NO. \_\_\_\_\_

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0'	2'	2'
CALICHE		2'	32'	30'
WHITE GRAVEL		32'	95'	63'
RED CLAY	WATER 75'	95'	115'	20'
WHITE CLAY + GRAVEL		115'	140'	25'
RED CLAY + GRAVEL		140'	250'	110'

8. WELL CONSTRUCTION  
 Diameter hole SIX inches Total depth 250 feet  
 Casing record 250' SIX INCH CASING  
 Weight per foot 15 Thickness 10 GAUGE  
 Diameter From To  
SIX inches 0 feet 250 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type CONCRETE  
 Depth of seal FIFTY - (50') feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 250 feet  
 Perforations:  
 Type perforation TORCH  
 Size perforation 3" LONG 3/16" WIDE  
 From 195 feet to 245 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 JUN 19 1991  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

9. WATER LEVEL  
 Static water level 72' 70" feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD ° F. Quality GOOD

Date started FEB. 19 1991  
 Date completed JUNE 14 1991

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name R.C.B.B. INC. Contractor  
 Address \_\_\_\_\_ Contractor  
 Nevada contractor's license number 020301  
 Nevada contractor's drillers number \_\_\_\_\_  
 Nevada driller's license number 1268  
 Actual Driller  
 Signed R.C.B.B. INC Contractor  
 Date JUNE 14, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>2</u>	<u>30</u>	<u>2</u>	<u>4 1/2</u>

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

