WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60744
Permit No.
Basin 212

NOTICE OF INTENT NO. 17669

1. OWNER Sands Hotel & Casino
MAILING ADDRESS 3355 Las Vegas Blvd South Las Vegas, NV 89109
ADDRESS AT WELL LOCATION 3355 South Las Vegas Blvd, Las Vegas, NV 89109

2. LOCATION NW ¼ SW ¼ Sec. 16 T 21 N/S R 61 E Clark County
PERMIT NO. MO-2728A (Issued by Water Resources) 162-16-202-008 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE CEC-6
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphaltic concrete		0	½	½
gravelly sand		½	2½	2
sand		2½	7½	5
caliche		7½	8	½
gravelly sand		8	10	2
caliche		10	12	2
silty sand		12	13	1
silty sand, w/gravel		13	25	12
clayey sand		25	26½	1½

Date started October 28, 19 96
Date completed October 28, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.157	0	30

Perforations:
Type perforation Factory Slot
Size perforation 0.020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-2 1/2 ft Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No Sand
From 4 feet to 30 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tom High
Address 731 Pilot Rd, Stett (Contractor) Las Vegas, NV 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed (By driller performing actual drilling on site or contractor)
Date 1-17-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627