

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 60153
Permit No. _____
Basin 212



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14995

1. OWNER Charles and Jesse Gutbrodt
MAILING ADDRESS 2001 Page Pahrump, NV 89048
ADDRESS AT WELL LOCATION 2001 Page

2. LOCATION NE 1/4 NW 1/4 Sec. 28 T 20S N/S R 53E E Nye County
PERMIT NO. 39-084-03 Calvada Valley
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Loam		0	5	15
Brown Clay		5	31	16
Brown Clay		31	50	19
Grey Calichia	x	50	64	14
Light Grey Clay	x	64	78	14
Grey Clay	x	78	94	16
Brown Popcorn	x	94	109	15
Brown Clay	x	109	125	16
Light Brown Clay	x	125	140	15

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet
HOLE DIAMETER (BIT SIZE)
From 12 3/4 Inches To 0 Feet 140 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation TORCH
Size perforation .25 x 6
From 77 feet to 98 feet
From 119 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Pahrump, NV 89048 Contractor
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date 1-28-97

Date started 1/21/97, 19____
Date completed 1/24/97, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>na</u>	<u>.50</u>

