



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15579

1. OWNER GRAND CASINOS, Inc ADDRESS AT WELL LOCATION 3755 Las Vegas Blvd So.  
 MAILING ADDRESS 130 CHESHIRE LANE  
MINNETONKA MN 55305

2. LOCATION NW 1/4 SW 1/4 Sec 21 T 21 R 61 E CLARK County  
 PERMIT NO. MO-2774 Issued by Water Resources Parcel No. 162-21-301-015 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thick-ness
Fill Asphalt over base		0	1	
SILTY SAND		1	7	
SANDY CLAY		7	10	
SILTY SAND		10	12 1/2	
SANDY CLAY		12 1/2	15	
SILTY CLAY		15	17	
SILTY SAND		17	18	
SANDY CLAY		18	21 1/2	
CALICHE		21 1/2	23	
Gravelly SAND - w/clay	Y	23	26 1/2	
SANDY CLAY	Y	26 1/2	29 1/2	
SILTY SAND	Y	29 1/2	30	
SANDY CLAY	Y	30	31 1/2	
CLAYEY SAND	Y	31 1/2	35 1/2	

8. WELL CONSTRUCTION  
 Depth Drilled 35 1/2 Feet Depth Cased 34 Feet

HOLE DIAMETER (BIT SIZE)  
 From 5 1/2 Inches To 35 1/2 Feet  
 From 0 Inches To 0 Feet  
 From 0 Inches To 0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>34</u>

Perforations:  
 Type perforation slotted screen  
 Size perforation 010 inch  
 From 19 feet to 34 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 18  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 18 feet to 35 1/2 feet

9. WATER LEVEL  
 Static water level 24.3 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 1/22, 1997  
 Date completed 1/22, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>N/A</u>			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Tim Allen of Terracon Consultants Contractor  
 Address 4343 S. Polaris Ave Contractor  
Las Vegas, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1944  
 Signed Thomas J. Beall  
 By driller performing actual drilling on site or contractor  
 Date 1-27-97