WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

1st Book

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60804
Permit No.
Basin 162

NOTICE OF INTENT NO. 15467

1. OWNER ANGOINE, CINDY
MAILING ADDRESS 6630 SURREY LANE
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION
6630 SURREY LANE

2. LOCATION NW 1/4 SW 1/4 Sec. 13 T 21S N/S R 53E E NYE County
PERMIT NO. ____ Issued by Water Resources | 44-611-07 Parcel No. | CONESTOGA COUNTRY ESTATES Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHIE		0	75	75
CALICHIE	WB	75	90	15
CLAY		90	105	15
CALICHIE	WB	105	128	23
CLAY		128	140	12

Date started 1/29/97, 19__
Date completed 1/31/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3
From 100 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 65 feet below land surfac
Artesian flow ____ G.P.M. ____ P.S.I
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Co. (Contractor)
Address PO BOX 4220 (Contractor)
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on-site or contractor)
Date 2/4/97

RECEIVED FEB 10 1997