WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60844
Permit No.
Basin 212

NOTICE OF INTENT NO. 17668

1. OWNER Avis Rent-A-Car
MAILING ADDRESS 5164 Rent-A-Car Road
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION Avis Rent-A-Car
5164 Rent-A-Car Road
Las Vegas, NV 89119

2. LOCATION SE ¼ NW ¼ Sec. 27 T 21 N/S R 61 E Clark County
PERMIT NO. MO-2522A (Issued by Water Resources) 162-27-201-005 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE VE-12
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG VE-12

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Silty Sand with gravel | | 0' | 8' | 8' |
| Caliche | | 8' | 15' | 7' |
| Silty Sand with gravel | | 15' | 20' | 5' |

DOWR/DWR Received FEB 11 199

Date started November 5, 1996
Date completed November 5, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8 Inches | 0 Feet | 20 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | 1.9 | 0.237 | 0 | 20 |

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-5' Cement 5'-7.5' Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 7.5' feet to 10 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119-4429
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed [signature]
By driller performing actual drilling on site or contractor
Date 2-10-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627