WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

1st Book

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 60890
Permit No.
Basin 230

# WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Chester or Cleeva LOWRY ADDRESS Lathrop Wells, Nevada 89020

2. LOCATION Lot 7 SE 1/4 NW ¼ SW ¼ Sec. 12 T. 17 N/S R. 48 E. Nye County
PERMIT NO. Domestic NA

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOP SOIL | 0 | 0 | 3 | 3 |
| HARD CEMENTED LIME | | 3 | 8 | 5 |
| MED HARD CEMENT LIME | | 8 | 11 | 3 |
| HARD CEMENTED LIME | | 11 | 22 | 11 |
| GRAY CLAY | | 22 | 26 | 4 |
| DARK GRAY CLAY | | 26 | 30 | 4 |
| BROWN CLAY | | 30 | 50 | 20 |
| GRAY CLAY | | 50 | 85 | 35 |
| CEMENTED SAND | 1 | 85 | 86 | 1 |
| GRAY SAND, CLAYS | | 86 | 115 | 29 |
| GRAY CEMENTED SAND | | 115 | 120 | 5 |
| BROWN CLAY | | 120 | 170 | 50 |
| GRAY CLAY | | 170 | 193 | 23 |
| CEMENTED SAND | | 193 | 196 | 3 |
| CLAY GREENISH GRAY | | 196 | 200 | 4 |

RECEIVED
MAY 3 1979
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started September 9, 19 78
Date completed 4-22, 19 79

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | NO TEST | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 200 feet
Casing record 8" 200'
Weight per foot 16.94 Thickness .188

| Diameter | From | To |
|---|---|---|
| 12 inches | 0 feet | 50 feet |
| 10 1/2 inches | 50 feet | 200 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 4" X 1/4" Inches
From 80 feet to 90 feet
From 180 feet to 200 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 57 ft. Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DONALD G. TRENARY
Address BOX 616B STAR RTE 15 LATHROP WELLS NV. 89020 C-D Co.
Nevada contractor's license number 14214 ~~D.C. Boyd~~
Nevada driller's license number 971
Signed Donald G. Trenary
Date April 26 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471