WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 60936
Permit No.
Basin 230

In Book

1. OWNER Mary Ann Loguda ADDRESS
Lot 8 Block 4 Forty Bas Estates
2. LOCATION SE ¼ NW ¼ Sec. 7 T. 17 N/S R. 52 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	11	11
Corse gravel		11		
+ Boulders			30	19
Rock		30	150	120

Note.
Stuck 8 5/8
Csg @ 120
Install 6 5/8 Liner

RECEIVED
DEC 28 1981
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 12-12, 19
Date completed , 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 150 feet
Casing record 8 5/8 6 5/8
Weight per foot Thickness 156

Diameter	From	To
8 5/8 inches	0 feet	120 feet
6 5/8 inches	116 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 150 feet

Perforations: 8 5/8 Torch 1/8 x 6 3 Rows
Type perforation 6 5/8 Saw .050 8 Rows
Size perforation
From 8 5/8 60 feet to 120 feet
From 6 5/8 120 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 34 Feet below land surface 34
Flow G.P.M.
Water temperature Cool ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Custom Drilling Ing
Address 4425 Stacey Ave L.V.
Nevada contractor's license number 016521
Nevada driller's license number 1081
Signed C B Capehart
Date 12-26-81

USE ADDITIONAL SHEETS IF NECESSARY

O-627