WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 60950
Permit No.
Basin 230

In Book

1. OWNER SUE SMITH ADDRESS
Well # 4

2. LOCATION SE ¼ NE ¼ Sec. 7 T. 17 N/S R. 52 E. NYE County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay + Gravel		0	62	62
Cmt Gravel		62	108	46
Clay		108	142	34
Cmt Gravel		142	150	8

RECEIVED
JUN 2 1980
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 4-24-, 1980
Date completed 4-30-, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 150 feet
Casing record 0 - 150
Weight per foot ..... Thickness 106A

Diameter		From		To	
8 5/8	inches	0	feet	150	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☑ No ☐ Type CMT
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation Factory
Size perforation 8 Rows
From 130 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 46 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LEE R. THOMAS
Address 5965 N. MAVERICK
Nevada contractor's license number 10831
Nevada driller's license number 623
Signed Lee R. Thomas
Date 5-29-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627