WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60980
Permit No.
Basin

NOTICE OF INTENT NO. 14635

1. OWNER James Dorner
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4719 S. Vickie Ann

2. LOCATION NE ¼ SW ¼ Sec 1 T 21S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 44-011-24 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	5	3
Clay		5	7	2
Calichie		7	11	4
Clay		11	18	7
Calichie		18	20	2
Clay		20	27	7
Calichie		27	32	5
Clay		32	42	10
Calichie		42	46	4
Clay		46	53	7
Calichie	WB	53	56	3
Clay		56	72	16
Calichie	WB	72	74	2
Clay		74	79	5
Calichie	WB	79	82	3
Clay		82	92	10
Calichie	WB	92	97	5
Clay		97	104	7
Calichie	WB	104	106	2
Clay		106	117	11
Calichie	WB	117	121	4
Clay		121	137	16
Calichie	WB	137	140	3

RECEIVED
MAY 16 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started April 28, 1995
Date completed May 4, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
12¼ Inches From 0 Feet To 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 8" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 5/5/95

Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627