WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61126
Permit No.
Basin

NOTICE OF INTENT NO. 3594

PRINT OR TYPE ONLY

1. OWNER JOHNNIE JOHNS
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 2 T. 21 S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) LOT 28 (Parcel No.) RANCHO VALLEY ESTATES (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	4	4
CALICHIE		4	5	1
CLAY		5	17	12
CALICHIE		17	19	2
CLAY		19	56	37
CALICHIE	WB	56	58	2
CLAY		58	66	8
CALICHIE	WB	66	67	1
CLAY		67	71	4
CALICHIE	WB	71	72	1
CLAY		72	78	6
CALICHIE	WB	78	80	2
CLAY		80	98	18
CALICHIE	WB	98	101	3
CLAY		101	117	16
CALICHIE	WB	117	119	2
CLAY		119	128	9
CALICHIE	WB	128	134	6
CLAY		134	140	6

RECEIVED
NOV 15 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-3, 1989
Date completed 11-6, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
..... inches
..... inches
Casing record 140' 8 5/8
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAWCUT
Size perforation ⅛ INCH BY 3 INCH
From 140 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 51 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S+H DRILLING (Contractor)
Address HCR BOX 70706 PAHRUMP NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-6-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627