WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 61179
Permit No.
Basin 162

NOTICE OF INTENT NO. 11136

1. OWNER Robin Adkins
MAILING ADDRESS
ADDRESS AT WELL LOCATION Quail Run

2. LOCATION SE ¼ NE ¼ Sec. 36 T. 19S N/S R. 52 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) | 28-233-04 (Parcel No.) | Bell Vista Unit 2 Lot 32 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	8'	8'
Calichie		8'	10'	2'
Clay		10'	32'	22'
Calichie		32'	34'	2'
Clay		34'	56'	22'
Calichie	WB	56'	58'	2'
Clay		58'	82'	24'
Calichie	WB	82'	84'	2'
Clay		84'	102'	18'
Calichie	WB	102'	104'	2'
Clay		104'	121'	17'
Calichie	WB	121'	123'	2'
Clay		123'	132'	9'
Calichie	WB	132'	134'	2'
Clay		134'	151'	17'
Calichie	WB	151'	153'	2'
Clay		153'	160'	7'

Date started 8-18, 1992
Date completed 8-21, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
SEP 1 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 160' Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0' Feet	160' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	160'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 160' feet to 50' feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed Steve Scearce (By driller performing actual drilling on site or contractor)
Date 8-25-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627