

OFFICE USE ONLY  
 Log No. 61426  
 Permit No. \_\_\_\_\_  
 Basin. ON

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34730

1. OWNER KEAT & LISA THURMAN ADDRESS AT WELL LOCATION 7065 GERMAIN  
 MAILING ADDRESS 7065 GERMAIN WINNEMUCCA NEVADA 89445  
 2. LOCATION NW 1/4 NW 1/4 Sec 18 T 35 N/S R 38 E Humboldt County  
 PERMIT NO. 10-451-52 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	5	5
ROCK SAND		5	20	15
ROCK AND GRAVEL		40	60	20
ROCK AND GRAVEL		60	120	60
ROCK SOME CLAY		120	140	20
ROCK AND SAND		140	160	20
CLAY SOME GRAVEL WATER		160	180	20
CLAY SOME GRAVEL WATER		180	200	20
LITTLE CLAY GRAVEL WATER		200	220	20

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 1/2 Inches 0 Feet 60 Feet  
6 7/8 Inches 60 Feet 220 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>250</u>	<u>+1</u>	<u>220</u>

Perforations:  
 Type perforation LOWERED  
 Size perforation 2 X 1/8  
 From 180 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 170 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started 10-1, 1996  
 Date completed 10-4, 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35</u>		<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AMERICAN Drilling Contractor  
 Address 3040 CALL HAN Contractor  
WINN N.V 89445  
 Nevada contractor's license number issued by the State Contractor's Board 0020578  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2032  
 Signed Harold Morris  
 By driller performing actual drilling or contractor  
 Date Oct. 9, 1996