


OFFICE USE ONLY
 Log No. 61548
 Permit No. _____
 Basin 110C


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30056

1. OWNER U.S. Army
 MAILING ADDRESS Hwy 95 No. Hawthorne NV.
 ADDRESS AT WELL LOCATION Max Home Army Depot
 2. LOCATION SE 1/4 SW 1/4 Sec. 8 T. 8N N/S R. 30 E MINERAL County
 PERMIT NO. WD 1092
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other ARCH

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		6/2	15	15
Silty sand		15	23	8
Sand		23	32	9
Sandy clay		32	34	2
Sand		34	43	9
Sandy silt		43	47	4
Sand	50'	47	77	30
Sandy clay		77	79	2
Silty sand		79	84	5
Sand		84	97	13

8. WELL CONSTRUCTION
 Depth Drilled 97 Feet Depth Cased 91 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 3/4 Inches To 6/2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Ech 40	PVC	6/2	86

Perforations:
 Type perforation Circumslot
 Size perforation 1.020
 From 86 feet to 91 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 84 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 84 feet to 97 feet

9. WATER LEVEL
 Static water level 46.3 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Allen Winters Contractor
 Address 1202 Kentucky Ave Woodland CA 95776 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 12852
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1941
 Signed Allen Winters
 By driller performing actual drilling on site or contractor
 Date 10-25-96

Date started 10-13, 1996
 Date completed 10-13, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 96 OCT 28 PM 1:16
 STATE ENGINEERS OFFICE