WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 62086
Permit No.
Basin 162

In Book #0606

1. OWNER Charles Jackson ADDRESS

2. LOCATION NW ¼ SE ¼ Sec. 31 T. 19 S N/S R. 53 E Nye County
PERMIT NO. Domestic

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dr. tan clay		0	45	45
tan, white clay		45	60	15
tan, white clay w/cali stks.		60	75	15
tan, white clay w/cali stks.		75	90	15
tan clay, cali stks		90	105	15
tan/br, clay, cali stks.		105	120	15
tan clay, cali stks		120	140	20

RECEIVED
JAN 20 1983
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 5-2, 1982
Date completed 5-3, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ~~Draw~~ down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 140 feet
Casing record 8 5/8
Weight per foot Thickness 188

Diameter	From	To
8 5/8 inches	140 feet	0 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation torch
Size perforation 1/4" by 12"
From 140 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name John Floyd
Address P.O. Box 292 Pahrump
Nevada contractor's license number 19268
Nevada driller's license number 588
Signed John Floyd
Date 5-13-82

USE ADDITIONAL SHEETS IF NECESSARY

O-627