


OFFICE USE ONLY  
 Log No. 62198  
 Permit No. \_\_\_\_\_  
 Basin 162



**WELL DRILLER'S REPORT**

Please complete this form in its entirety *in book*

NOTICE OF INTENT NO. 8804

PRINT OR TYPE ONLY

1. OWNER Ed Hutler ADDRESS AT WELL LOCATION Mesquite  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE  $\frac{1}{4}$  Sec. 32 T. 19s N/S R. 53 E. NYE County  
 PERMIT NO. N/A Issued by Water Resources 29-802-23 Parcel No. lot 11 block 3 unit 6 Rancho Del Sol Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	4'	4'
caliche		4'	6'	2'
clay		6'	18'	12'
caliche		18'	20'	2'
clay		20'	40'	20'
caliche		40'	43'	3'
clay		43'	54'	11'
caliche	WB	54'	56'	2'
clay		56'	62'	6'
caliche	WB	62'	65'	3'
clay		65'	72'	7'
caliche	WB	72'	76'	4'
clay		76'	86'	10'
caliche	WB	86'	89'	3'
clay		89'	98'	9'
caliche	WB	98'	101'	3'
clay		101'	118'	17'
caliche	WB	118'	123'	5'
clay		123'	130'	7'
caliche	WB	130'	133'	3'
clay		133'	135'	2'
caliche	WB	135'	138'	3'
clay		138'	140'	2'

8. WELL CONSTRUCTION  
 Diameter 12 1/2 inches Total depth 140' feet  
 Casing record 140' x 8 5/8"  
 Weight per foot 16.94 Thickness .188  

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50' feet  
 Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8" x 3"  
 From 140' feet to 120' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 DEC 07 1990

Div. of Water Resources  
 Date started Branch Office 11/5/90 19 90  
 Date completed 12-9 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 39 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING Contractor  
 Address HCR 65 Box 80358 Pahrump, Nv 89041 Contractor  
 Nevada contractor's license number 30880 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1426 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Wm Brown By driller performing actual drilling on site or contractor  
 Date 12-6-90

