DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 62246
Permit No.
Basin

1. OWNER Norman Wilson ADDRESS Kellogg Road

2. LOCATION SW ¼ SE ¼ Sec. 16 T. 21 N/S R. 54 E. County
PERMIT NO. Domestic

3. TYPE OF WORK
[New Well ☐] Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
[Domestic ☐] Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ [Rotary ☐]
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil Blow Sand		0	6	6
Gravel				
Sandy		6	17	11
Gravel		17	22	05
Sand		22	24	02
Gravel		24	27	03
Red Sand		27	30	03
Caliche		30	31	01
Gravel		31	32	01
Brown Sand		32	37	05
Gravel		37	42	05
Red Sandy clay		42	43	01
White Sandy Clay		43	46	03
Gravel		46	48	02
Caliche with Rock		48	53	05
Caliche with clay strks		53	55	02
White Clay		55	65	05
Brown Sandy clay		65	72	07
" " "		72	93	21
Caliche		93	108	15
Hard Caliche		108	114	06
Clay w/ Caliche strks		114	120	06
Clay		120	122	02
Clay with strks of Gravel		122	200	78

Date started 7/30, 19 72
Date completed 7/31, 19 72

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
FEB 27 1973
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 inches Total depth 200 feet
Casing record 8 5/8 10 gage
Weight per foot 12.50 Thickness 10 gage

Diameter	From	To
8 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: [Yes ☐] No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: [Yes ☐] No ☐
Gravel packed from 200 ft feet to 50 feet

Perforations:
Type perforation Torch Cut
Size perforation 1/4" X 8" X 3 Rounds
From 60 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 68 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ron Floyd Pump Co
Address P.O. Box 157 Pahrump
Nevada contractor's license number 7479
Nevada driller's license number 476
Signed Kenny E. Floyd
Date 8/1/72

USE ADDITIONAL SHEETS IF NECESSARY

5471