WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 62316
Permit No.
Basin 162

NOTICE OF INTENT NO. 16946

1. OWNER Thomas Kerr
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3761 Dyer St.

2. LOCATION NW ¼ NW ¼ Sec. 13 T 20S N/S R 52 E NYE County
PERMIT NO. (Issued by Water Resources) 28-703-05 (Parcel No.) Charleston Park Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3'
Caliche		3	5	2'
Clay		5	14	9'
Caliche		14	17	3'
Clay		17	21	4'
Caliche		21	23	2'
Clay		23	36	13'
Caliche		36	41	5'
Clay		41	51	10'
Caliche.	WB.	51	54	3'
Clay		54	63	9'
Caliche	WB	63	65	2'
Clay		65	72	7'
Caliche	WB.	72	76	4'
Clay		76	85	9'
Caliche	WB	85	87	2'
Clay		87	99	12'
Caliche	WB	99	102	3'
Clay		102	114	12'
Caliche	WB.	114	116	2'
Clay		116	125	9'
Caliche	WB.	125	128	3'
Clay		128	137	9'
Caliche	WB	137	139	2'
Clay		139	140	1'

DCNR/DWR Received FEB 21 1996 LAS VEGAS OFFICE

Date started 1-25, 1996
Date completed 1-27, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. box 4220 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 2-10-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627