

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 62468
 Permit No. _____
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28488

1. OWNER GRANT CONSTRUCTION CO. ADDRESS AT WELL LOCATION 1820 T. WALKER
 MAILING ADDRESS MINDEN, NV MINDEN, NV

2. LOCATION SW 1/4 NE 1/4 Sec. 26 T. 13 N. R. 20 E. DOUGLAS County
 PERMIT NO. 23-130-04 EAST VALLEY Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	4	4
COBELS		4	7	3
CEMENTED GRAVEL/COBELS		7	14	7
SANDY CLAY/COBELS		14	27	13
GRAVEL/SANDY CLAY		27	59	32
GRAVEL SAND		59	72	23
SANDY CLAY/GRAVEL		72	115	43
SANDY CLAY/COBELS		115	224	109
SAND	✓	224	226	2
CLAY		226	234	8
SANDY CLAY SAND/STRAK ✓		234	260	26

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>260</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 1/8
 From 220 feet to 260 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 260 feet

9. WATER LEVEL
 Static water level: 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 10/22, 1996
 Date completed 11/8, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 879 RITTELL DR Contractor
GARDNERSVILLE, NV 89410
 Nevada contractor's license number 27673A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11-8-96