

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21358

1. OWNER Ken Ballard ADDRESS AT WELL LOCATION 15 Pine Street
MAILING ADDRESS Yerington, Nevada
2. LOCATION NW 1/4 SE 1/4 Sec 16 T 13 N/S R 25 E Wyon County
PERMIT NO. N/A Issued by Water Resources Parcel No. 14-411-10 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Soil</u>		<u>0</u>	<u>3</u>	
<u>Sand And Gravel</u>		<u>3</u>	<u>26</u>	
<u>Cemented Gravel</u>	<u>1</u>	<u>26</u>	<u>260</u>	
<u>Sand And Gravel</u>		<u>260</u>	<u>340</u>	

DATE: 10-10-76
TIME: 11:10
WELL DRILLER'S NAME: [Signature]

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)
From 0 Inches To 260 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>1300</u>	<u>0.219</u>	<u>71</u>	<u>260</u>

Perforations:
Type perforation Tough cut
Size perforation 1/4 x 6 long slots
From 260 feet to 260 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 0-50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 10-1, 19 76
Date completed 10-12, 19 76

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Produced about 8 Gallons a min</u>		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Techwell Drilling Contractor
Address PO Box 599 Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031891
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1872
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 10-12-76