



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33044

1. OWNER Bill Ricci ADDRESS AT WELL LOCATION 1 1/2 miles SW of Ely
 MAILING ADDRESS 1000 Mt. View Drive
Ely, NV 89301

2. LOCATION SW 1/4 SE 1/4 Sec. 21 T. 16 N/R 63 E White Pine County
 PERMIT NO. A-2 FILE # 296060 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
Gravel		1	40	39
Clay & Gravel		40	45	5
Gravel		45	50	5
Clay & Gravel		50	55	5
Sand & Gravel		55	185	130
Clay Sand & Gravel		185	305	120
Clay / Sand & Gravel	x	305		
Water Seams			340	35
Clay & Sand		340	345	5
Clay / Sand & Gravel	x	345		
Water Seams			420	75

RECEIVED
 96 NOV 18 AM 10:52
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 420 Feet Depth Cased 420 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 420 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	420

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 280 feet to 420 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 ft
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 420 feet

9. WATER LEVEL
 Static water level 290 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue
Ely, Nevada 89301 Contractor
 Nevada contractor's license number 14790 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed Jerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date November 12, 1996

Date started November 5, 19 96
 Date completed November 12, 19 96

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>7 1/2 H.P.</u>	<u>31</u>	<u>10</u>	<u>4</u>