WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety In Book

OFFICE USE ONLY
Log No. 626627
Permit No.
Basin 163

1. OWNER Earl Roofner ADDRESS Box 467 Star Rt-70 Jean Nv 89019
Lot 4 217-89
2. LOCATION SW ¼ NE ¼ Sec. 6 T. 25 N/S R. 57 E. Clark County
PERMIT NO.

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
White Clay		4	9	5
Green Clay		9	15	6
Ben Clay	31	15	31	16
Caliche		31	34	3
Ben Clay		34	41	7
Caliche		41	43	2
Ben Clay		43	68	23
Coral		68	70	2
Ben Clay		70	76	6
Coral		76	79	3
Ben Clay		79	81	2
Coral		81	85	4
Ben Clay		85	91	6
Coral		91	96	5
Ben Clay		96	99	3
Coral		99	104	5
B. Clay		104	107	3
Coral		107	116	9
Wht Clay		116	118	2
Coral		118	122	4
White Clay		122	126	4
Coral		126	129	3
White Clay		129	133	4
Coral		133	141	8
White Clay		141	143	2
Coral		143	149	6
Clay		149	150	1

Date started Oct 10, 19 81
Date completed Oct 17, 19 81

7. WELL TEST DATA

RECEIVED AUG 20 1982 Div. of Water Resources Branch Office — Las Vegas, Nev.

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 4 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 17 inches Total depth 150 feet
Casing record 8 5/8 188 WA 11
Weight per foot 23 Thickness 188 WA 11

Diameter	From	To
inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 50 feet

Perforations:
Type perforation 1/8 x 6" Slotted
Size perforation Flame Cut Vert
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 Feet below land surface
Flow G.P.M.
Water temperature 66 °F. Quality Very Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bill Ray Blood
Address 1610 E La Madre Way
Nevada contractor's license number 13264
Nevada driller's license number 838
Signed Robert Spurlock
Date

USE ADDITIONAL SHEETS IF NECESSARY

O-627