WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 62632
Permit No.
Basin 163

1. OWNER HENRY, RODGERS ADDRESS 1950-16th ST #L117 Newport Beach, CAL.

2. LOCATION ½ of NE ¼ NE ¼ Sec. 7 T. 25 S N/S R. 57 E. CLARK County
PERMIT NO. 40 Acres SANDY VALLEY, NEV KINGSTON ROAD

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOP SOIL | | 0 | 6 | |
| COLETCHIE | | 6 | 22 | |
| GRAY CLAY | | 22 | 48 | |
| COLETCHIE | | 48 | 70 | |
| Red CLAY | | 70 | 93 | |
| COLETCHIE | | 93 | 96 | |
| Red CLAY | | 96 | 132 | |
| COLETCHIE | | 132 | 140 | |
| GRAY CLAY | | 140 | 180 | |
| Red CLAY | | 180 | 192 | |
| COLETCHIE | | 192 | 200 | |

RECEIVED
APR 17 1979
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started April 6, 1979
Date completed APRIL 12, 1979

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 50 Draw down 4 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 200 feet
Casing record 8 INCH
Weight per foot 12 LBS Thickness 10 GAGE

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 200 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 FT feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation TOUCH CUT
Size perforation 1/8
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 22 Feet below land surface 22
Flow G.P.M.
Water temperature COLD F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HOWARD T. EKENBERG
Address STAR ROUT BOX 1050 DEAN, NEV
Nevada contractor's license number 7484
Nevada driller's license number 679
Signed Howard T. Ekenberg
Date April 16, 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471