WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 62653
Permit No. 41168
Basin 162

NOTICE OF INTENT NO. 16636

OWNER Tim Hafen Ranches Inc.,
MAILING ADDRESS 1321 S. Hwy 160
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
Field

2. LOCATION SE ¼ NW ¼ Sec. 9 T. 21 N/S R 54 E Nye County

PERMIT NO. 17884 - 0 18070 - 24159 (Cert#7957) - 41168 (APN#45-101-01)
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
■ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ■ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
■ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown Clay		4	32	28
Clay w/small gravel		32	52	20
Brown & Grey Clay		52	97	45
Hard Form Linestone	X	97	110	13
Brown Clay		110	232	122
Hard Limestone	X	232	235	3
Gravel	X	235	242	7
Brown Clay		242	258	16
Hard Limestone		258	260	2
Gravel	X	260	264	4
Brown Clay		264	306	42
Hard Brown Clay		306	314	8
Soft Brown Clay	X	314	340	26
Brown Clay		340	380	40
Tough Brown Clay		380	402	22

Received MAR 10 1997

Date started Jan 16, 19 97
Date completed Feb 27, 19 97

7. WELL TEST DATA
TEST METHOD: ■ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	0	¼

8. WELL CONSTRUCTION
Depth Drilled 402 Feet Depth Cased 402 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
18 Inches	0 Feet	402 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	35#	.250	0	402

Perforations:
Type perforation Torch Cut
Size perforation 3/8" wide x 8" long
From 242 feet to 402 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ■ Yes ☐ No
Depth of Seal 50'
Placement Method: ■ Pumped ☐ Poured
Seal Type: ■ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ■ Yes ☐ No
From 50 feet to 402 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Contractor
Address 1060 W. Basin Rd Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg
By driller performing actual drilling on site or contractor
Date 2-28-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627