

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 62798  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17261

1. OWNER Coast Hotels & Casinos ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 40 Broadbent 833 Nevada Hwy #1, Boulder City, NV 4300 W Carey Rd, No. Las Vegas  
 2. LOCATION SE 1/4 SW 1/4 Sec 18 T 20 N 8 R 1 E CLARK County  
 PERMIT NO. NO-2779 139-18-404-001 Parcel No. N/A Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From ft	To ft	Thickness ft
SILTY SAND		0	3	3
CAUCHE		3	6	3
GRAVEL		6	8	2
CAUCHE		8	16	8
GRAVEL		16	18	2
SILTY SAND		18	19	1
CAUCHE	21	19	21	3
CLAY		21	26	5

8. WELL CONSTRUCTION  
 Depth Drilled 26 Feet Depth Cased 26 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 26 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 1/4</u>		<u>1/8</u>	<u>0</u>	<u>23.5</u>

Perforations:  
 Type perforation Sawcut  
 Size perforation 0.020  
 From 23.5 feet to 26 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped with 3% bentonite  
 Poured  
 Gravel Packed:  Yes  No  
 From 21.5 feet to 26 feet

9. WATER LEVEL  
 Static water level 21 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started February 19 1997  
 Date completed February 19 1997

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Weber Drilling Services  
 Address 115 So. Weber Dr. Suite 1 Chandler, Az 85226  
 Nevada contractor's license number 39528  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the M1847  
 Division of Water Resources, the on-site driller  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 3-6-97