


OFFICE USE ONLY  
 Log No. 62833  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15806

1. OWNER SHELDON & JOAN FOX ADDRESS AT WELL LOCATION 1531 WEST HICKORY  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SW 1/4 Sec. 29 T. 20-S. N/S R. 53 E NVE County \_\_\_\_\_  
 PERMIT NO. 40-383-06 CALVADA VALLEY UNIT 5 BLOCK 7  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown clay		4	8	4
Gray clay & caliche		8	24	16
Green clay		24	36	12
Gray clay		36	54	18
Gray clay & caliche	x	54	86	32
Limestone		86	90	4
Gray clay		90	106	16
Brown clay		106	121	15
Brown clay & caliche	x	121	140	19

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:  
 Type perforation Torch cut  
 Size perforation 1/4" width 8" long  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

Date started March 3 19 97  
 Date completed March 3 19 97

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

9. WATER LEVEL  
 Static water level 54 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim Pike Well Drilling, LLC Contractor  
 Address P.O. Box 56 Contractor  
Pahrump, Nevada 89041

Nevada contractor's license number 17563A  
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on site driller 1812

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date March 7, 1997