

MWS

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 62976  
Permit No. 090  
Basin

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.

1. OWNER Del Webb Corp  
MAILING ADDRESS 6001 N. 24th ST  
Phoenix, Az. 85016  
2. LOCATION SW 1/4 NE 1/4 Sec. 27 T. 13 N/S R. 18 E Douglas County  
PERMIT NO. M0429-B Issued by Water Resources Parcel No. Subdivision Name

ADDRESS AT WELL LOCATION Highway 50, Stirling, NV  
Hartman's Horizon Casino

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt w/ sand</u>		<u>0</u>	<u>4</u>	
<u>Sand w/ silt</u>		<u>4</u>	<u>9</u>	
<u>Sand, some silt, trace</u>		<u>9</u>	<u>20</u>	
<u>Silty silt</u>		<u>20</u>	<u>29</u>	

8. WELL CONSTRUCTION  
Depth Drilled 29 Feet Depth Cased 28 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 Inches To  
Inches Feet Feet  
Inches Feet Feet  
Inches Feet Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
4" scft 40  
Perforations:  
Type perforation slot .010  
Size perforation  
From 28 feet to 8 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 7'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
#3 sand  
Gravel Packed:  Yes  No  
From 28' feet to 7' feet

Date started 11/16/85, 19\_\_\_\_  
Date completed 1, 19\_\_\_\_

9. WATER LEVEL  
Static water level 12' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name James M Young Contractor  
Address 1416 Mosswood Ln.  
Modesto CA 95355 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 34699  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1969  
Signed James M Young  
By driller performing actual drilling on site or contractor  
Date 12-8-85