WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63118
Permit No.
Basin 162

NOTICE OF INTENT NO. 14605

1. OWNER Donald Bradley
MAILING ADDRESS
ADDRESS AT WELL LOCATION 700 W. Pilt Lane

2. LOCATION NE ¼ NW ¼ Sec. 9 T. 20 S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 35-161-23 (Parcel No.) Calvegas Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	13	7
Calichie		13	17	4
Clay		17	22	5
Calichie		22	24	2
Clay		24	35	11
Calichie		35	38	3
Clay		38	50	12
Calichie	WB	50	54	4
Clay		54	61	7
Calichie	WB	61	63	2
Clay		63	72	9
Calichie	WB	72	75	3
Clay		75	81	6
Calichie	WB	81	87	6
Clay		87	92	5
Calichie	WB	92	94	2
Clay		94	103	9
Calichie	WB	103	111	8
Clay		111	118	7
Calichie	WB	118	125	7
Clay		125	135	10
Calichie	WB	135	140	5

Date started March 29, 19 95
Date completed April 3, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
APR 08 1995
Div. of Water Resources
Branch Office Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 18" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on site or contractor)
Date 4/26/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627