

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 63352
 Permit No. 087
 Basin.....

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27274

Consultant: _____
 1. OWNER: CDM Engineers & Constructors Client: _____
 MAILING ADDRESS: 50 W. Liberty, Suite 770 ADDRESS AT WELL LOCATION: Santa Fe Pipeline
Reno, Nevada 89501 Vista Canyon Group Sparks Solvent/Fuel Site
Sparks, Nevada
 2. LOCATION: SW 1/4 NE 1/4 Sec 9 T. 19N N/S R. 20 E Washoe County _____
 PERMIT NO. M/O 913 E-4 34-101-42 Sparks Solvent/Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray brown subangular to subround sand w/ angular to subround gravel, abundant gravel, minor silt, med. dense, dry		0	30	30
Abundant boulders below 22ft.				
Color change to lt. red brown, no boulders below 34ft.				
Lt. brown sand w/ gravel abundant cobbles, minor silt, med. dense, saturated		30	55	25.

8. WELL CONSTRUCTION
 Depth Drilled 55 Feet Depth Cased 53 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 1/2 Inches 0 Feet 55 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	w/cap	SCH 80 PVC	0	22.2
6"		SS Sump w/cap	47.6	53.
Centralizers		47,34,21 SS		

Perforations:
 Type perforation Factory sawed slot
 Size perforation .100 slot SS wire wrapped
 From 22.2 feet to 47.6 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 3 - 17.2 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 17.2 - 19.2
 Gravel Packed: Yes No 1/4-1/8" Well sand
 Filter From 19.2 - 20.2 feet to 20.2 - 55 feet

Date started 8-9-95, 19____
 Date completed 8-10-95, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
no test			

9. WATER LEVEL
 Static water level not know feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board. 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date February 6, 1996