WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65021
Permit No.
Basin 162

NOTICE OF INTENT NO. 16078

1. OWNER Van Buskirk, Esther
MAILING ADDRESS VICKIE ANN
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION
VICKIE ANN ROAD

2. LOCATION NW 1/4 SW 1/4 Sec. 36 T 21S N/S R 53E E NYE County
PERMIT NO. _____ Issued by Water Resources | 44-771-46 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHIE		0	115	115
CALICHIE	WB	115	140	25
GRAVEL	WB	140	165	25
CEMENTED GRAVEL		165	175	10

DCNR/CWR Received MAY 16 1997 LAS VEGAS OFFICE

Date started 4/27/97, 19__
Date completed 5/2/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	175	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	175

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3
From 135 feet to 155 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 175 feet

9. WATER LEVEL

Static water level 65 feet below land surfac
Artesian flow _____ G.P.M. _____ P.S.I
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Co.
Contractor

Address PO BOX 4220
Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dan
By driller performing actual drilling on-site or contractor

Date 5/9/97