WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65032
Permit No.
Basin 212

NOTICE OF INTENT NO. 15728

1. OWNER Southern Nevada Water Authority
MAILING ADDRESS 1850 E. Flamingo Road
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION ≈ 1800 feet north of East Desert Inn Road and ≈ 100 feet east of the Las Vegas Wash

2. LOCATION SW ¼ SE ¼ Sec. 10 T. 21 N/S R. 62 E. Clark County
PERMIT NO. Issued by Water Resources | 161-10-896-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE 0-33B
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG 0-33B

Material	Water Strata	From	To	Thickness
Sandy Silt		0'	6'	6'
Silty clay		6'	12'	6'
Silty Sand		12'	26'	14'
Sandy Clay		26'	40'	14'

Date started March 28, 1997
Date completed March 28, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	40

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 20 feet to 40' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-1' neat cement, 16'-18' bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 18 feet to 40 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High
Address 731 Pilot Road, Suite H
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed
By driller performing actual drilling on site or contractor
Date 5-9-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627