WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65037
Permit No.
Basin 212

NOTICE OF INTENT NO. 15724

1. OWNER Southern Nevada Water Authority
MAILING ADDRESS 1850 E. Flamingo Road, Las Vegas, NV 89119
ADDRESS AT WELL LOCATION ≈ 80 feet South of Sahara Ave and ≈ 10 feet east of the Sloan Channel

2. LOCATION SE ¼ SW ¼ Sec. 3 T. 21 N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) 161-10-196-002 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE 0-10A
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG 0-10A

Material	Water Strata	From	To	Thickness
Sandy Lean Clay w/gypsum		0	11'	11'
Clayey Sand		11'	22'	11'
Sandy Clay		22'	28'	6'
Clayey Sand		28'	31'	3'
Sandy Clay		31'	34'	3'
Clayey Sand		34'	38'	4'
Sandy Clay		38'	40'	2'

Date started March 13, 1997
Date completed March 13, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 38 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8	0	40

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	38

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 18 feet to 38 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-1' neat cement, 13.5-15.5' bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15.5 feet to 38 feet

9. WATER LEVEL
Static water level 9.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed (By driller performing actual drilling on site or contractor)
Date 4-30-97

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627