



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15625

1. OWNER City of Las Vegas - Office of Business Development ADDRESS AT WELL LOCATION Southeast corner of Las Vegas Blvd. South and Clark Avenue
 MAILING ADDRESS 400 Las Vegas Blvd South Las Vegas, NV 89101

2. LOCATION NE 1/4 SW 1/4 Sec. 34 T. 20 N. R. 61 E Clark County
 PERMIT NO. MU-2762A Issued by Water Resources Parcel No. 139-34-310-04, -062, -063, -074 and 139-34-710-01 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE MW-5
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other Auger

6. LITHOLOGIC LOG MW-5

Material	Water Strata	From	To	Thickness
Sandy Silt		0'	1'	1'
Silt		1'	2'	1'
Clayey Silt		2'	3'	1'
Silty Clay		3'	4'	1'
Sandy Silty Clay		4'	7.5'	3.5'
Silty Clay		7.5'	10'	2.5'
Caliche		10'	12'	2'

8. WELL CONSTRUCTION
 Depth Drilled 12 Feet Depth Cased 12 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 Inches To 12 Feet
 From 0 Feet To 12 Feet
 From 0 Feet To 12 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.164</u>	<u>0.154</u>	<u>0</u>	<u>14</u>

Perforations:
 Type perforation Factory Slot
 Size perforation 0.020"
 From 2 feet to 12 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 0' - 1'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 1' feet to 12 feet

9. WATER LEVEL
 Static water level 7.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started February 25 19 97
 Date completed February 25 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thomas High Contractor
 Address 731 Pilot Road, Suite H Las Vegas, NV 89119 Contractor
 Nevada contractor's license number _____ issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
 Signed _____ By driller performing actual drilling on site or contractor
 Date 4-23-97