WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65047
Permit No.
Basin 212

NOTICE OF INTENT NO. 17713

1. OWNER Clark County Dept. of Aviation
MAILING ADDRESS P.O. Box 11005
Las Vegas, NV 89111-1005
ADDRESS AT WELL LOCATION 4811 S. Paradise Road
Las Vegas, NV 89109

2. LOCATION SE ¼ SW ¼ Sec. 22 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MO-2778 Issued by Water Resources
162-22-402-003 Parcel No.
Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE MW-9: [ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG MW-9

Material	Water Strata	From	To	Thickness
Asphalt		0'	3"	3"
Fill		3"	1'	9"
Gravelly Lean Clay		1'	5'	4'
Lean Clay		5'	8'	3'
Clayey Sand		8'	9'	1'
Clay with gravel		9'	13'	4'
Silty gravel		13'	14'	1'
Caliche		14'	17'	3'
Gravelly Lean Clay		17'	20'	3'
Caliche		20'	23'	3'
Sandy Gravel w/ clay		23'	24'	1'
Lean Clay		24'	28'	4'
Clayey Gravel		28'	31'	3'
Clay with gravel		31'	32'	1'

Date started February 13, 1997
Date completed February 13, 1997

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 32 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
5	0	32

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	32

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Depth of Seal
Placement Method: [ ] Pumped [X] Poured

Gravel Packed: [X] Yes [ ] No
From 6 feet to 30 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F. Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson
Contractor
Address 731 Pilot Road, Suite H
Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed
By driller performing actual drilling on site or contractor
Date 4-23-97

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627