WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65147
Permit No.
Basin 161

NOTICE OF INTENT NO. 30465

1. OWNER Robert Bond
MAILING ADDRESS 8600 Pioneer Way
Fallon, Nv 89406

ADDRESS AT WELL LOCATION 8600 Pioneer Way
Fallon, Nv 89406

2. LOCATION NW ¼ NE ¼ Sec. 23 T 19 N/S R 27 E Chruchill County

PERMIT NO. (Issued by Water Resources) | 7-151-27 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	15	15
Brown Clay		15	21	6
Brown Sand		21	33	12
Gray Sand		33	50	17
Brown Sand		50	60	10
Gray Clay		60	67	7
Gray Sand		67	80	13
Brown Clay		80	83	3
Gray & Brownish Sand		83	110	27
Gray Clay		110	133	23
Gray Sand		133	142	9
Brown Sand		142	160	18
Brown Clay		160	175	15
Brown Sand	X	175	200	25

Date started April 30, 1996
Date completed April 30, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	200

Perforations:
Type perforation Mill Cut
Size perforation 1/8 inch
From 195 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nv 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-13-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627