

OFFICE USE ONLY  
 Log No. 65153  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33167

1. OWNER Ed Aro ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. BOX 90 4223 Rancheria  
Fallon, NV. 89407 Fallon, NV. 89406

2. LOCATION SW 1/4 NE 1/4 Sec. 16 T. 19 N/S R. 28 E Churchill County  
 PERMIT NO. 8-122-13 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	7	7
Brown Clay		7	26	19
Brown SAND		26	34	8
Brown Clay		34	35	1
Gray Sand Clay		35	44	9
Brown Sand		44	54	10
Gray Clay		54	56	2
Gray Sand		56	57	1
Gray Clay		57	72	15
Gray Sand		72	82	10
Gray Clay		82	92	10
Gray Sand		92	112	20
Brown Clay		112	114	2
Brown Sand		114	121	7
Gray Sand		121	136	15
Gray Clay		136	138	2
Gray Sand		138	156	18
Gray Clay		156	159	3
Gray Sand		159	179	20
Gray Clay		179	183	4
Brown Clay		183	187	4
Brown Sand	X	187	196	9

8. WELL CONSTRUCTION  
 Depth Drilled 196 Feet Depth Cased 196 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 196 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	196

Perforations:  
 Type perforation Well Screen  
 Size perforation .030  
 From 191 feet to 196 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 180  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 180 feet to 198 feet

9. WATER LEVEL  
 Static water level 10' 2" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality Unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. Contractor  
 Address P.O. BOX 1265 Contractor  
FALLON, NV. 89407-1265  
 Nevada contractor's license number 29064  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1753  
 Division of Water Resources, the on-site driller  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 8-1-96

Date started July 1, 1996  
 Date completed July 8, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)